Project No. W-\_\_\_-



pa15a(01/99)

## NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION BUREAU OF SAFE DRINKING WATER TECHNICAL REVIEW FORM

AERATION (N.J.A.C. 7:10-11.15(a))

Water Purveyor  Type:		PWSID#	Municip	Municipality			
		Air flow r Water flow A:W ratio	w rate:	- -			
Dimensions:		Constructi	ion Material:				
				YES	NO	N/A	
1. Does all air entering an induced or forced air aeration unit pass through a corrosion-resistant screen of not less than 24 mesh?							
2. Are the aeration units constructed so as to prevent contamination by birds, insects, wind-borne debris, rainfall and water draining off the exterior of the aerator?							
3. Are all forced air aeration units equipped with air filters, including a filter to remove entrained oil when applicable?			g a filter				
***Submit ap	ppropriate engineering pla	ans, specifications, reports, etc. t	to substantiate yo	ur answe	ers. ***	:	
I hereby certi approval.	fy that answers provided	herein are accurate and reflectiv	ve of the project be	eing con	sidered	for	
Signature of Engineer Professional Engineer's Embossed Seal		Date		N.J.P.E. #			
Type or Print	Name of Engineering Fire	rm					